



RZ3/4

VdS tested and approved by the building authority

Product Description

The DIBt building rules list requires a verification of applicability for fire protection closures (a German approval from the building inspectorate or a European technical approval). These approvals stipulate a locking device when the systems are to be kept open in operation. The locking device must be suitable. Its applicability must be verified by means of an approval from the building inspectorate.

construction type	control units	Type of protection:	IP 65
proof	Z-6.5-1484		
Fire alarm analysis	Pushbutton • Via fire alarm loop or smoke switch • Potential-free contact of central fire alarm system		
